

Optimization of Solar Energy Harvesting Using IoT-Based Monitoring Systems in Saudi Arabia

Mohammed Abdul Lateef^{1*}

¹Research Scholar

***Corresponding Author**
Mohammed Abdul Lateef
Research Scholar

Article History

Received: 06.08.2026

Accepted: 30.09.2026

Published: 08.10.2026

Abstract: Saudi Arabia has exceptional solar resources, rapidly growing electricity demand and a national commitment to energy diversification. The performance of photovoltaic systems, however, is affected by high module temperature, dust deposition, irradiance variability, equipment degradation, communication gaps and maintenance quality. Internet of Things monitoring can improve solar-energy harvesting by connecting field sensors, smart meters, inverters, weather stations and maintenance systems to a governed operational platform. This integrative review evaluates how IoT monitoring supports real-time performance assessment, fault detection, soiling management, predictive maintenance, energy forecasting and quality assurance in Saudi photovoltaic installations. It examines system architecture, sensor selection, communications, data quality, cybersecurity, analytics and human decision-making. The paper proposes a framework that converts trustworthy measurements into normalized performance indicators, diagnostic alerts, controlled work orders and verified energy outcomes. It emphasizes that connectivity alone does not optimize generation; benefits depend on calibrated instruments, appropriate baselines, reliable communications, interpretable analytics and timely field action. Black-box optimization without local validation can conceal sensor error or environmental effects. For Saudi Arabia, the recommended approach prioritizes temperature and soiling correction, geographically appropriate communication, secure integration with SCADA, and phased deployment across utility, industrial and distributed systems. The framework supports Vision 2030 through renewable-energy productivity, efficient operations, local technical capability and evidence-based asset management.

Keywords: Solar Energy Harvesting, Internet of Things, Photovoltaic Monitoring, Performance Optimization, Predictive Maintenance, Soiling, Saudi Arabia, Vision 2030.

Copyright © 2026 The Author(s): This is an open-access article distributed under the terms of the Creative Commons Attribution 4.0 International License (CC BY-NC 4.0) which permits unrestricted use, distribution, and reproduction in any medium for non-commercial use provided the original author and source are credited.

1 INTRODUCTION

Solar photovoltaic generation converts an abundant Saudi resource into electricity without fuel combustion at the point of use. Installed capacity is expanding across utility-scale plants, industrial sites, commercial facilities and distributed applications. Yet nameplate capacity does not guarantee delivered energy. Module temperature, dust, shading,

mismatch, inverter availability, cable losses, tracker performance and maintenance response determine how much usable electricity reaches the grid or facility.

Monitoring is therefore central to solar-energy harvesting. Conventional systems record inverter output and selected weather variables, but

Citation: Lateef, M. A. (2026). Optimization of Solar Energy Harvesting Using IoT-Based Monitoring Systems in Saudi Arabia; *Glob Acad J Econ Buss*, 8(5), 1652-1661. <https://doi.org/10.36348/gajeb.2026.v08i05.052>

modern Internet of Things architectures can connect granular sensors, edge devices, gateways, cloud services, SCADA platforms and maintenance applications. This connectivity allows operators to compare expected and actual generation, identify abnormal strings, quantify soiling, detect thermal stress and prioritize intervention. The operational objective is not to collect maximum data; it is to obtain sufficient trustworthy evidence for timely decisions.

Saudi conditions create both opportunity and challenge. Solar irradiance is high, but ambient heat reduces photovoltaic conversion efficiency. Dust and sand can obscure modules, while cleaning consumes water, labor and access time. Remote project locations require robust communications and autonomous diagnostics. Coastal humidity and salinity affect enclosures and connections. Monitoring strategies developed in temperate climates cannot be transferred without environmental calibration.

IoT deployment also introduces dependencies. Low-cost sensors may drift, wireless links may fail, timestamps may differ and cybersecurity weaknesses may expose control interfaces. Analytics can produce false alerts if baselines ignore temperature, irradiance or curtailment. A successful system must integrate electrical engineering, instrumentation, communications, data governance, quality assurance and maintenance.

The subject aligns with the research scholar's background in SCADA, electrical systems, commissioning, QA/QC, reliability and industrial project management. This paper therefore treats IoT solar monitoring as an operational and quality system rather than a stand-alone digital application.

2 AIM OBJECTIVES AND RESEARCH QUESTIONS

The aim is to develop an integrated framework for optimizing solar-energy harvesting through IoT-based monitoring in Saudi Arabia.

The objectives are to identify major environmental and technical causes of photovoltaic underperformance; examine suitable IoT architectures, sensors and communications; explain how monitoring data can support diagnostics, maintenance and cleaning; integrate quality and cybersecurity controls; and define implementation priorities aligned with Saudi Vision 2030.

The research questions are: Which variables provide the most useful evidence of energy loss? How should IoT data be normalized and converted into

reliable operational decisions? Which architecture and communication choices suit Saudi solar environments? How can cybersecurity, calibration and quality assurance protect monitoring integrity? What phased approach can scale from pilot systems to large portfolios?

3 REVIEW METHODOLOGY

An integrative review design was used because the topic spans photovoltaics, sensors, communications, analytics, maintenance, energy management and industrial control. The conceptual search scope included Scopus, Web of Science, IEEE Xplore, ScienceDirect and standards repositories. Search concepts combined solar photovoltaic, energy harvesting, IoT monitoring, soiling, module temperature, fault detection, performance ratio, predictive maintenance, wireless sensor networks, SCADA and Saudi Arabia.

Priority was given to peer-reviewed research and authoritative standards relevant to photovoltaic monitoring and IoT systems. Sources were considered where they explained measurement methods, loss mechanisms, data architectures, fault diagnosis, forecasting, maintenance or security. Studies without clear technical methods, purely promotional claims and findings unrelated to field operation were excluded from the synthesis.

Evidence was grouped into resource and environment, architecture, measurement, communications, analytics, operation, quality, security and implementation. Because studies use different climates, system sizes, sensor sets and outcome definitions, results were synthesized qualitatively rather than pooled statistically. No fabricated screening counts or universal savings percentages are presented. The proposed framework requires validation against site-specific equipment, climate, tariffs, grid requirements and operating procedures.

Seasonal interpretation is necessary because summer heat, winter irradiance, wind and rainfall change both expected output and loss mechanisms. A dashboard should compare performance with an appropriate seasonal baseline rather than a single annual threshold. After storms or unusual dust events, temporary loss may justify inspection before cleaning. Following rainfall, apparently clean reference sensors and modules should be checked for uneven residue. These contextual rules reduce unnecessary dispatch and help operators distinguish normal environmental variation from equipment deterioration.

4 Solar Energy Harvesting under Saudi Conditions

Photovoltaic output depends on incident irradiance, cell temperature, spectral conditions, angle of incidence and electrical conversion efficiency. Saudi sites often receive strong irradiance, but high temperature creates a counteracting loss because module voltage and efficiency decline as cells heat. Monitoring should therefore measure or estimate module temperature rather than comparing power only with irradiance.

Dust and sand deposition are major operational variables. Soiling reduces transmitted light and may create nonuniform patterns that increase mismatch. Loss depends on particle properties, wind, humidity, tilt, rainfall and cleaning history. A single regional soiling factor is inadequate. Paired reference devices, clean-versus-soiled sensors, image methods or normalized energy trends can support site-specific decisions.

Shading may arise from structures, vegetation, adjacent rows, accumulated dirt or tracker misalignment. Electrical mismatch can develop through module ageing, damaged bypass diodes, connector resistance and string imbalance. Inverter clipping, efficiency, downtime and control limitations also affect harvested energy. Grid curtailment must be separated from equipment underperformance so that maintenance teams are not assigned to losses they cannot correct.

Environmental monitoring should include irradiance, ambient temperature, module

temperature and relevant weather variables. Wind influences module cooling and dust movement. Humidity and rainfall affect soiling and corrosion. The required sensor density depends on plant area and microclimate variation. Additional sensors should be justified by the decisions they improve, since excessive instrumentation increases calibration and maintenance burden.

A credible baseline uses normalized indicators. Specific yield compares energy with installed capacity. Performance ratio relates delivered energy to in-plane irradiance while accounting for reference conditions. Availability distinguishes whether equipment was capable of operating. Loss trees can allocate differences among temperature, soiling, downtime, clipping, wiring and curtailment. Definitions and data boundaries must remain consistent over time.

Architecture selection should include maintainability. Devices require accessible isolation, clear labeling, replacement procedures and supported firmware. Gateways installed in harsh enclosures need thermal assessment and surge protection. Spare strategy should cover failure-prone communication and sensor components. The design should also state what happens when a vendor service ends. Documented protocols and exportable data reduce the risk that monitoring capability becomes unusable before the photovoltaic assets reach the end of their operating life.

Table 1: Principal solar-loss mechanisms and IoT evidence

Loss mechanism	Monitoring evidence	Operational response
Temperature	Module and ambient temperature with irradiance	Normalize output and review cooling or mounting
Soiling	Soiling sensor, reference pair and yield trend	Optimize zone-specific cleaning
Electrical mismatch	String current, voltage and thermal evidence	Inspect modules, connectors and bypass paths
Inverter downtime	Status, alarms, temperature and energy gap	Prioritize diagnosis and repair
Curtailment	Grid command and plant capability	Separate commercial loss from equipment fault

5 IoT Monitoring Architecture

An IoT solar-monitoring system can be described in layers. Field devices measure weather, electrical and equipment states. Edge devices acquire, validate and aggregate signals. Gateways connect local networks to supervisory or cloud platforms. Applications provide visualization, alarms, analytics and work-management integration. Governance controls identifiers, access, configuration and data retention across all layers.

At field level, inverter and meter data should be combined with independent reference measurements. Relying entirely on one device can conceal a common measurement error. Smart combiner boxes, string current sensors, tracker controllers, protection devices and thermal sensors may provide deeper visibility where consequence justifies cost. Distributed rooftop systems may use fewer points and portfolio-level comparison.

Edge computing is valuable in remote or bandwidth-constrained locations. Local rules can detect missing data, calculate summaries and retain information during communication loss. Critical protection and safe control must remain local and should not depend on cloud availability. When connectivity returns, buffered records require timestamp and sequence checks before synchronization.

Platform integration should maintain separation between monitoring and control. Read-only exchange may be appropriate for many analytics. Commands to inverters, trackers or cleaning equipment require authorization, validation, interlocks and audit trails. Interfaces with SCADA, computerized maintenance management and energy-management systems should use defined data ownership and failure behavior.

Scalability requires a stable naming model. Each plant, inverter, string, sensor and communication device needs a unique identifier connected to location, rating and configuration. Metadata should include engineering units, valid range, sampling interval, calibration status and quality flag. Without this context, portfolio analytics may compare unlike signals or interpret stale values as real operating conditions.

Measurement uncertainty should be matched to the decision. Portfolio screening may tolerate greater uncertainty than contractual performance verification or warranty claims. The monitoring plan should define uncertainty budgets for important derived indicators and identify which input dominates. When a calculated loss is smaller than measurement uncertainty, dispatching a field team may not be justified. Reporting uncertainty also prevents minor numerical differences from being interpreted as real performance changes.

6 Sensors Measurement Quality and Calibration

Sensor quality determines the ceiling of analytical quality. Pyranometers, reference cells and irradiance sensors have different response characteristics, accuracy and maintenance needs. Selection should consider the intended uncertainty, spectral response, temperature behavior and cleaning regime. A sensor installed at the wrong tilt or allowed to soil differently from the array can distort performance assessment.

Electrical measurements include direct-current voltage and current, alternating-current power, energy, power factor, frequency and equipment status. Meter class, wiring, current-transformer ratio, polarity and synchronization should be verified during commissioning. String-level

measurement can locate localized faults, while inverter-level measurement may be sufficient for smaller systems. The design should match the diagnostic requirement.

Module temperature can be measured using attached sensors or estimated from environmental models. Attached sensors require correct placement and thermal contact. One point may not represent a large array with different wind or mounting conditions. Thermography can identify hotspots, connector heating and diode problems, but interpretation depends on irradiance, loading, angle, emissivity and inspection method.

Calibration is not an administrative formality. Drift can create apparent degradation or improvement. The programme should define calibration intervals, reference standards, as-found and as-left results, field verification and rules for handling data collected while a sensor was out of tolerance. Quality flags should travel with measurements into dashboards and analytics.

Commissioning should verify end-to-end data integrity. A field stimulus or known operating event should be traced through sensor, gateway, database, display and alarm. Units, scaling, timestamps, sign convention and asset mapping must be checked. This process prevents visually convincing dashboards from concealing systematic errors.

Remote sites need power resilience for monitoring equipment. Gateways, network switches and reference sensors may depend on auxiliary supplies that fail during the same event being investigated. Backup duration should support the required diagnostic record, and restart behavior should preserve clocks and configuration. Communication alarms should differentiate a failed device from a failed backhaul. This distinction directs technicians correctly and prevents lost connectivity from being mistaken for plant outage.

7 Communications and Data Management

Communication choice depends on distance, terrain, device density, bandwidth, power availability and criticality. Wired industrial networks provide predictable performance within plant areas. Cellular and long-range wireless technologies can connect dispersed assets. Short-range wireless may suit rooftop or sensor clusters. Satellite may support remote locations where terrestrial coverage is limited. Hybrid architectures often provide the best balance.

Reliability should be designed rather than assumed. Link budgets, antenna placement,

interference, environmental enclosures and power backup require engineering review. Monitoring should identify packet loss, latency, gateway health and clock status. Store-and-forward capability preserves data during interruption, while local alarms protect urgent functions.

Sampling rates should reflect process dynamics. Irradiance and power require intervals capable of representing cloud transients and equipment response, whereas slow environmental variables may need less frequent collection. Excessive sampling increases storage and network load without improving decisions. Aggregation rules must preserve peaks, outages and quality information.

Data management should retain raw or appropriately granular records for investigation while providing validated operational datasets. Missing values should not be silently interpolated for compliance or performance reporting. Corrections, substitutions and modelled values require clear flags. Time synchronization is essential when comparing irradiance, inverter response, protection events and maintenance actions.

Retention policy should consider warranty, degradation analysis, dispute resolution and research needs. Access should be role based. Data exports and interfaces should avoid vendor lock-in by using documented formats where practical. Ownership must be clear when platforms are hosted by engineering contractors, equipment vendors or service providers.

Peer comparison is effective when equipment is genuinely comparable. Strings should have similar orientation, module type, shading and operating state. Inverters may have different firmware, loading or clipping behavior. Analytics should exclude assets under maintenance or curtailment and retain the reason for exclusion. A peer group that changes silently can shift the baseline and conceal degradation. Governance should therefore version group membership and review it after plant modification.

Model validation should include abnormal and normal periods. A detector that performs well only during clear-sky operation may generate excessive alarms during variable clouds. Validation should report precision, recall, energy consequence, detection lead time and false-alarm burden. Operators should be able to see the variables supporting a diagnosis. When confidence is low, the platform should recommend verification rather than presenting an uncertain classification as a confirmed fault.

8 Analytics for Performance Optimization

The first analytical task is performance normalization. Actual power should be compared with an expected value derived from irradiance, temperature, installed capacity, equipment availability and known operational constraints. A fixed threshold is inadequate because expected output changes continuously. Baselines may use physical models, historical clean performance or carefully validated machine-learning methods.

Fault detection can operate at several levels. Rule-based checks identify missing signals, limit violations and inconsistent states. Statistical methods detect deviations from peers or historical behavior. Machine learning can model complex relationships, but it requires representative training data and monitoring for drift. Diagnostic outputs should identify likely causes and confidence, not only label an anomaly.

Soiling optimization compares expected energy recovery with cleaning cost, water use, access risk and forecast weather. Cleaning every array at a fixed interval may waste resources, while delayed cleaning sacrifices energy. IoT evidence can support zone-specific schedules. Automated cleaning systems require confirmation that they operate effectively and do not damage modules.

Predictive maintenance uses trends in inverter temperature, fan operation, fault codes, string imbalance, insulation alarms and communication health. The purpose is to create sufficient lead time for intervention. An alert should connect to a defined inspection or work order. False-positive burden, missed detections and maintenance outcomes should be measured.

Forecasting supports grid and facility planning. Short-term forecasts combine weather information with plant behavior; longer horizons support maintenance and energy budgeting. Forecast error should be reported by horizon and weather regime. Curtailment and outages must be treated separately to avoid training models on artificial underproduction.

Optimization recommendations must remain within electrical, warranty, grid and safety constraints. Models should not change inverter settings or tracker behavior without approved authority. Human review is particularly important when data quality is uncertain or recommended action affects availability.

Cleaning verification should compare normalized performance before and after work while considering irradiance and temperature. Visual

appearance alone is insufficient. Records should identify cleaned zones, method, water use, timing and any damage found. If performance does not recover, the loss may arise from sensor error, electrical mismatch or equipment condition. This feedback prevents repeated cleaning from masking a different failure mechanism and improves future scheduling.

9 Maintenance Quality Assurance and Operational Response

Monitoring creates value only when the organization responds. Alarm rationalization should define the abnormal condition, consequence, priority, responsible role and expected action. Duplicate and chattering alarms should be corrected. Operators need overview displays that separate plant-wide resource changes from equipment-specific problems.

Work-management integration should retain the evidence behind an alert. The work order should identify asset, symptoms, relevant trends, diagnostic confidence and required safety controls. Field findings should return to the monitoring system so that models and thresholds can be evaluated. Closure should confirm performance recovery, not only completion of a task.

Quality assurance covers equipment receipt, installation, commissioning, calibration, documentation and corrective action. Module identification, connector compatibility, cable routing, earthing, torque, enclosure integrity and protection settings influence long-term performance. Construction defects may appear later as monitoring anomalies; traceability helps distinguish design, installation and operating causes.

Nonconformities should state the requirement, evidence and immediate control. Root-cause analysis should consider recurring defects across equipment families. Corrective actions require verification. Where an underperforming asset remains in service, temporary controls, monitoring frequency, owner and expiry date should be documented.

Performance reviews should combine energy and reliability. Useful measures include normalized yield, performance ratio, availability, soiling loss, inverter downtime, alarm response, defect closure and sensor validity. Energy gains should not be claimed when caused by favorable weather, changed curtailment or revised data treatment.

Security procurement should address support duration, vulnerability notification, secure update mechanisms and access logging. Low-cost devices may become unmanaged when suppliers

discontinue platforms. Asset owners need inventories of hardware, firmware, certificates and external connections. Risk acceptance should consider whether a device can be isolated or replaced without disrupting generation. Security review should be repeated when remote-service arrangements or control interfaces change.

10 Cybersecurity Privacy and Resilience

IoT expands the digital attack surface through field devices, wireless links, gateways, remote services and application interfaces. Compromise can disrupt monitoring, manipulate performance data or provide a path toward control systems. Security must be designed according to consequence and system architecture.

Device identity, strong authentication, least privilege, secure configuration, encrypted communications where appropriate, network segmentation and controlled remote access form the foundation. Default credentials and unmanaged vendor accounts should be prohibited. Firmware and configuration changes require testing, approval and rollback arrangements.

Monitoring networks should be separated from safety-critical and protection functions. Gateways require logging, health monitoring and backup. Cloud services need contractual clarity regarding data location, retention, incident notification and recovery. Security controls must remain maintainable over the expected plant life.

Resilience includes offline operation, buffered data and trusted restoration. The organization should know how to rebuild gateways, recover configurations and verify data integrity after an incident. Exercises should involve operations, electrical engineering, information technology, cybersecurity and vendors. A system that cannot recover reliably may reduce rather than improve operational confidence.

The framework should use staged autonomy. Early deployment can provide advisory alerts that engineers review. After accuracy and operating procedures are proven, selected low-consequence actions may be automated within limits. Higher-consequence commands should remain approved and interlocked. This progression allows the organization to learn how models behave under local conditions and prevents premature automation from turning uncertain analytics into physical control.

11 Integrated IoT Solar Optimization Framework

The proposed framework begins with operational objectives and a verified asset model. The facility defines which losses and decisions matter,

then selects measurements capable of resolving them. Commissioning establishes trustworthy sensors, scaling, timestamps and baseline performance. Secure communications and edge validation transport data with quality status.

The analytical layer normalizes output for resource and temperature, then allocates losses among soiling, equipment condition, downtime, wiring, clipping and curtailment. Alerts are prioritized by energy consequence, safety, confidence and response urgency. Recommendations enter controlled cleaning, inspection or maintenance workflows. Field results verify whether the action recovered performance.

The final layer reviews outcomes and updates models. Sensor drift, false alerts, missed faults and changing environmental conditions feed back into calibration, thresholds and architecture. This learning cycle prevents the platform from becoming a static dashboard.

Governance crosses every layer. Asset identifiers, access rights, calibration, configuration, model version, data correction and decision authority require named owners. High-consequence actions remain subject to engineering review. The framework measures success through verified energy and reliability outcomes rather than connected-device counts.

Portfolio governance should allow local variation within common standards. Central teams can define naming, cybersecurity, quality flags and performance metrics, while site teams calibrate environmental thresholds and maintenance responses. Central comparison can identify systemic inverter or module issues, whereas local expertise interprets weather and access conditions. Clear division of responsibility prevents centralized dashboards from bypassing the engineers who understand the plant.




Figure 1: Integrated IoT framework for solar-energy optimization
Source: Author synthesis

12 Saudi Arabia Vision 2030 and Implementation Priorities

IoT-enabled solar optimization supports Saudi energy diversification by increasing the usable output and reliability of installed photovoltaic capacity. The strongest Vision 2030 alignment is operational: better renewable-asset productivity, reduced avoidable loss, efficient water and maintenance use, digital capability and local engineering development.

Implementation should begin with a representative pilot that includes weather sensing, inverter data, selected string measurements, communications health and maintenance integration. The baseline should cover seasonal conditions before savings are claimed. Pilot evaluation should document data availability, diagnostic accuracy, response time, recovered energy and operating cost.

Utility plants, industrial facilities and distributed rooftops require different architectures.

Large plants justify granular sensors and dedicated networks. Industrial sites benefit from SCADA and energy-management integration. Distributed portfolios need standardized gateways, remote diagnostics and scalable device management. A single design should not be imposed on every use case.

Saudi environmental calibration is essential. Sites should quantify local soiling, temperature behavior, rainfall, wind and cleaning effectiveness. Coastal and desert locations may need different enclosure, corrosion and communication strategies. Water scarcity should influence cleaning optimization.

Local capability can be developed through joint projects among operators, universities, laboratories, integrators and equipment suppliers. Knowledge transfer should include sensor validation, data engineering, cybersecurity, analytics and field maintenance. Complex methods should be adopted

only when local teams can understand, challenge and sustain them.

The findings also show that operational feedback is a data source. Technician observations, replaced components, photographs and restoration tests can label events more accurately than automated signals alone. Integrating this evidence supports supervised learning and rule improvement. Feedback fields should be simple enough for field use but controlled enough for analysis. Poorly structured free text may retain knowledge for one person while remaining unusable for portfolio learning.

13 DISCUSSION

The review shows that IoT improves solar-energy harvesting through visibility, normalization, diagnosis and coordinated response. Sensors establish environmental and electrical context. Communications make dispersed evidence available. Analytics convert data into likely loss mechanisms. Maintenance and cleaning actions recover performance. Quality assurance verifies that measurements and interventions are trustworthy.

The main limitation of technology-led approaches is the assumption that more connectivity produces more energy. Poorly placed sensors, inconsistent metadata, missing calibration and ungoverned algorithms can generate false conclusions at scale. The optimization chain is only as strong as its weakest measurement or decision process.

Saudi conditions make temperature, soiling and communication reliability priority design variables. They also strengthen the case for edge processing and site-specific baselines. Portfolio comparisons should normalize climate and equipment differences. Performance targets transferred from another region may be unrealistic or misleading.

Economic evaluation should compare recovered energy and avoided downtime with sensors, networks, licenses, calibration, cybersecurity, cleaning and maintenance costs. Benefits should be verified against a documented baseline and adjusted for weather, curtailment and equipment changes. This discipline supports credible investment decisions.

Experimental studies should also compare alternative cleaning triggers under the same environmental and commercial assumptions. Energy recovery alone is not sufficient because a strategy may increase water consumption, equipment wear or worker exposure. Researchers should report the condition of reference sensors, module technology, tilt, particle characteristics and weather during each trial. Replication across seasons would clarify whether a threshold remains effective as dust composition and rainfall change. Open reporting of uncertainty and operational constraints would make results more useful to Saudi asset owners selecting practical control rules.

Table 2: Balanced measures for IoT solar-monitoring performance

Dimension	Illustrative measure	Why it matters
Energy	Normalized yield and recoverable loss	Separates resource from controllable performance
Reliability	Availability and repeated fault time	Tracks sustained generation capability
Data quality	Valid sensor coverage and calibration status	Protects analytical credibility
Maintenance	Response and verified recovery time	Connects alerts to operational value
Resilience	Communication uptime and restoration test	Supports dependable remote operation

14 Research Gaps and Future Research

Longitudinal Saudi datasets are needed to characterize soiling, temperature loss, sensor drift and equipment degradation across regions. Research should compare monitoring architectures using consistent definitions of energy recovery, diagnostic accuracy, water use and life-cycle cost. Unsuccessful pilots and false alerts should be reported.

Future studies should investigate interpretable models that combine physical knowledge with machine learning. Uncertainty estimates are necessary when data are missing or environmental conditions fall outside training ranges. Digital twins could test cleaning, tracker and inverter strategies before field deployment.

Research is also needed on cybersecurity, communication resilience, device lifecycle and workforce interaction. Human factors determine whether operators trust alerts and whether maintenance feedback improves models. Common anonymized data structures could accelerate research while protecting commercially sensitive information.

Investment approval should include recurring costs. Sensors require calibration and replacement; communication services require subscriptions; analytics require support; and cybersecurity requires monitoring and updates. A low initial price can create higher life-cycle cost if devices fail rapidly or data cannot be exported. The

business case should compare alternative architectures over the expected service period and include the cost of maintaining evidence quality.

15 Practical Managerial and Policy Implications

Managers should define operational decisions before purchasing sensors. Engineering teams should own asset models, measurement requirements and acceptance criteria. QA/QC should control calibration, installation and records. Operations should own alarm response, while maintenance should verify field outcomes. Cybersecurity should approve connectivity and remote access.

Contracts should require documented interfaces, data export, device management, security support and knowledge transfer. Acceptance testing should include communication loss, sensor failure, incorrect scaling, time synchronization, alarm routing and recovery. Performance guarantees should distinguish equipment capability from weather and grid curtailment.

Policy can support standardized terminology, calibration capability, interoperability, cybersecurity and professional development. Incentives should reward verified energy and reliability outcomes rather than device deployment alone. Water and environmental impacts should be considered in cleaning optimization.

Regular governance reviews should confirm that monitoring priorities still match plant objectives, asset condition, grid arrangements and available maintenance capability.

16 Limitations

This integrative review combines heterogeneous studies, standards and technical guidance. It does not provide a meta-analysis or a universal percentage improvement. Solar technologies, climates, tariffs, communication coverage and maintenance practices differ. No original Saudi plant dataset was available. The framework therefore requires site-specific validation, cybersecurity review and calibration against equipment, grid and regulatory requirements.

17 CONCLUSION

IoT-based monitoring can improve solar-energy harvesting in Saudi Arabia when trustworthy measurements are connected to normalized analysis, controlled decisions and verified field action. The most important applications are performance-loss allocation, soiling optimization, fault detection, predictive maintenance, forecasting and communication-health management.

Successful implementation requires calibrated sensors, reliable timestamps, resilient communications, governed metadata, interpretable analytics, cybersecurity and competent maintenance response. Connectivity without these foundations can increase complexity without recovering energy. Algorithms should support engineering judgment and remain bounded by safety, warranty and grid requirements.

The proposed framework links objectives, asset models, sensing, edge validation, secure transport, loss analytics, work management and feedback. It is suitable for phased adaptation across utility, industrial and distributed systems. By improving renewable-asset productivity, operational efficiency and local digital capability, this approach offers a practical contribution to Saudi Vision 2030.

REFERENCES

- International Electrotechnical Commission. (2021). IEC 61724-1 Photovoltaic system performance - Monitoring. <https://webstore.iec.ch/en/publication/65561>
- International Electrotechnical Commission. (2016). IEC 62446-1 Photovoltaic systems - Testing, documentation and maintenance. <https://webstore.iec.ch/en/publication/24057>
- International Electrotechnical Commission. (2021). IEC 61215 Terrestrial photovoltaic modules - Design qualification and type approval. <https://webstore.iec.ch/en/publication/61345>
- International Electrotechnical Commission. (2020). IEC 61730 Photovoltaic module safety qualification. <https://webstore.iec.ch/en/publication/59803>
- International Organization for Standardization. (2018). ISO 50001 Energy management systems - Requirements with guidance for use. <https://www.iso.org/standard/69426.html>
- International Organization for Standardization. (2015). ISO 9001 Quality management systems - Requirements. <https://www.iso.org/standard/62085.html>
- International Electrotechnical Commission. (2018). IEC 62443-4-2 Security for industrial automation and control system components. <https://webstore.iec.ch/en/publication/34421>
- Mani, M., and Pillai, R. (2010). Impact of dust on solar photovoltaic performance: Research status, challenges and recommendations. *Renewable and Sustainable Energy Reviews*, 14(9), 3124-3131. <https://doi.org/10.1016/j.rser.2010.07.065>
- Sarver, T., Al-Qaraghuli, A., and Kazmerski, L. L. (2013). A comprehensive review of the impact of dust on solar energy systems. *Renewable and Sustainable Energy Reviews*, 14(9), 3124-3131.

- Sustainable Energy Reviews, 22, 698-733. <https://doi.org/10.1016/j.rser.2012.12.065>
- Ilse, K., Micheli, L., Figgis, B. W., et al. (2019). Techno-economic assessment of soiling losses and mitigation strategies for solar power generation. *Joule*, 3(10), 2303-2321. <https://doi.org/10.1016/j.joule.2019.08.019>
 - Micheli, L., Muller, M., and Deceglie, M. G. (2019). A review of soiling estimation methods for photovoltaic modules. *IEEE Journal of Photovoltaics*, 9(6), 1727-1736. <https://doi.org/10.1109/JPHOTOV.2019.2940828>
 - Sayyah, A., Horenstein, M. N., and Mazumder, M. K. (2014). Energy yield loss caused by dust deposition on photovoltaic panels. *Solar Energy*, 107, 576-604. <https://doi.org/10.1016/j.solener.2014.05.030>
 - Jordan, D. C., and Kurtz, S. R. (2013). Photovoltaic degradation rates - An analytical review. *Progress in Photovoltaics*, 21(1), 12-29. <https://doi.org/10.1002/pip.1182>
 - Köntges, M., Kurtz, S., Packard, C., et al. (2014). Review of Failures of Photovoltaic Modules. IEA PVPS Task 13. <https://iea-pvps.org/key-topics/review-of-failures-of-photovoltaic-modules-final/>
 - Madeti, S. R., and Singh, S. N. (2017). Monitoring system for photovoltaic plants: A review. *Renewable and Sustainable Energy Reviews*, 67, 1180-1207. <https://doi.org/10.1016/j.rser.2016.09.088>
 - Triki-Lahiani, A., Bennani-Ben Abdelghani, A., and Slama-Belkhodja, I. (2018). Fault detection and monitoring systems for photovoltaic installations: A review. *Renewable and Sustainable Energy Reviews*, 82, 2680-2692. <https://doi.org/10.1016/j.rser.2017.09.101>
 - Mellit, A., and Kalogirou, S. A. (2008). Artificial intelligence techniques for photovoltaic applications: A review. *Progress in Energy and Combustion Science*, 34(5), 574-632. <https://doi.org/10.1016/j.pecs.2008.01.001>
 - Livera, A., Theristis, M., Makrides, G., and Georghiou, G. E. (2019). Recent advances in failure diagnosis techniques based on performance data analysis for grid-connected photovoltaic systems. *Renewable Energy*, 133, 126-143. <https://doi.org/10.1016/j.renene.2018.09.101>
 - Dhimish, M., Holmes, V., Mehrdadi, B., and Dales, M. (2017). Comparing Mamdani Sugeno fuzzy logic and RBF ANN network for PV fault detection. *Renewable Energy*, 113, 182-192. <https://doi.org/10.1016/j.renene.2017.05.066>
 - Haque, A., Bharath, K. V. S., Khan, M. A., Khan, I., and Jaffery, Z. A. (2019). Fault diagnosis of photovoltaic modules. *Energy Science and Engineering*, 7(3), 622-644. <https://doi.org/10.1002/ese3.255>
 - Pearsall, N. (Ed.). (2017). *The Performance of Photovoltaic Systems*. Woodhead Publishing. <https://doi.org/10.1016/C2015-0-04518-4>
 - Akyildiz, I. F., Su, W., Sankarasubramaniam, Y., and Cayirci, E. (2002). Wireless sensor networks: A survey. *Computer Networks*, 38(4), 393-422. [https://doi.org/10.1016/S1389-1286\(01\)00302-4](https://doi.org/10.1016/S1389-1286(01)00302-4)
 - Al-Fuqaha, A., Guizani, M., Mohammadi, M., Aledhari, M., and Ayyash, M. (2015). Internet of Things: A survey on enabling technologies, protocols, and applications. *IEEE Communications Surveys and Tutorials*, 17(4), 2347-2376. <https://doi.org/10.1109/COMST.2015.2444095>
 - Gubbi, J., Buyya, R., Marusic, S., and Palaniswami, M. (2013). Internet of Things: A vision, architectural elements, and future directions. *Future Generation Computer Systems*, 29(7), 1645-1660. <https://doi.org/10.1016/j.future.2013.01.010>
 - Bedi, G., Venayagamoorthy, G. K., Singh, R., Brooks, R. R., and Wang, K. C. (2018). Review of Internet of Things for electric power and energy systems. *IEEE Internet of Things Journal*, 5(2), 847-870. <https://doi.org/10.1109/JIOT.2018.2802704>